

ORNL
MASTER COPY



OAK RIDGE NATIONAL LABORATORY

operated by

UNION CARBIDE CORPORATION

NUCLEAR DIVISION

for the

U.S. ATOMIC ENERGY COMMISSION



Def
ORNL - TM - 733 (2nd. Revision)

COPY NO. -

62

DATE - September 19, 1966

MSRE DESIGN AND OPERATIONS REPORT

Part VI

OPERATING SAFETY LIMITS FOR THE MOLTEN-SALT
REACTOR EXPERIMENT

S. E. Beall
R. H. Guymon

NOTICE This document contains information of a preliminary nature and was prepared primarily for internal use at the Oak Ridge National Laboratory. It is subject to revision or correction and therefore does not represent a final report.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

MSRE DESIGN AND OPERATIONS REPORT

Part VI

OPERATING SAFETY LIMITS FOR THE MOLTEN-SALT REACTOR EXPERIMENT

S. E. Beall
R. H. Guymon

This document has been prepared at the request of the U. S. Atomic Energy Commission to set the limits for various parameters related to the Molten-Salt Reactor Experiment. In some cases the limits report the level at which the reactor will be shut down by automatic monitoring devices. In all cases the reactor operators are obligated to take steps intended to correct a parameter which is temporarily outside the specified range indicated herein.

1.0 Containment

1.1 Leakage from the primary system as indicated by the reactor and drain-tank-cell air activity will not exceed the equivalent of 4 liters of salt after 120 days of operation at full power, as estimated in the case of the Most Probable Accident.¹ Offgas activity release will be limited to fission-product concentrations averaging less than 1.5×10^{-4} $\mu\text{c}/\text{cc}$ in the stack.² Fission-product release will be monitored by radiation monitors on the offgas lines and at the stack.

1.2 The cover-gas supply pressure will be kept at 30 psig or greater and the leak-detector system pressure above 50 psig to help prevent excessive exposure to operating personnel, as specified in Chapter 0524 of the AEC Manual.³

¹S. E. Beall et al., "MSRE Design and Operations Report, Part V, Reactor Safety Analysis Report," USAEC Report ORNL TM-732, Oak Ridge National Laboratory, August, 1964.

²Based on 3×10^{-9} $\mu\text{c}/\text{cc}$ as permissible concentration at ground level downstream of the stack. An atmospheric dilution of 0.5×10^5 is assumed.

³Chapter 0524, "Standards for Radiation Protection."

1.0 Containment (continued)

- 1.3 The radioactivity in the reactor cell service lines will be maintained at a level sufficiently low to prevent excessive exposure to personnel, as specified in Chapter 0524 of the AEC Manual.
- 1.4 The pressure in the reactor and drain tank cells will be maintained below atmospheric pressure during reactor operation.
- 1.5 The maximum reactor and drain-tank-cell leak rate will not be allowed to exceed 1% of the cell volume per day, calculated for the conditions of the Maximum Credible Accident.¹ The in-leakage rate will be determined at least once per week.
- 1.6 The maximum vapor-condensing system pressure (under nonaccident conditions) will not exceed 3 psig.
- R2 1.7 During reactor operation the level of water in the vapor-condensing tank shall be checked at least once a week to insure that it remains in the range required for proper operation (8000 to 9300 gallons).
- 1.8 The building high-bay pressure will be maintained at slightly less than atmospheric pressure (~ 0.1 in. H_2O) during all operations in which the high bay serves as the secondary containment.
- 1.9 The ventilation system filters will be tested at least annually and after each change of filters.
 - 1.9.1 The measured efficiency of the filters must be greater than 99.9% for 0.5μ and larger particles, as indicated by the standard dioctylphthalate test.
- R2 1.10 All reactor and drain-tank-cell shield blocks shall be in place and secured by the hold-down devices whenever fuel salt is in the reactor vessel.

2.0 Fuel System

- 2.1 The maximum steady-state power level is 10 Mw (administrative limit).

2.0 Fuel System (continued)

- 2.2 The power level for safety-rod scram trip is 15 Mw or less.
- 2.3 The temperature level for safety-rod scram trip is less than 1400°F. Adjustment of the trip between 1300 and 1400°F will require administrative approval.
- 2.4 The maximum fuel system cover-gas pressure is 50 psig.
- 2.5 The maximum salt fill rate while filling the core is 1.0 ft³/min.
- 2.6 The maximum amount of ²³⁵U which will be added at one time is 120 g. During operation fuel will only be added through the sampler-enricher.
- 2.7 The maximum concentration of fissionable material in the fuel salt will not exceed by more than 5% the minimum required for full-power operation at 1200°F with equilibrium xenon and the control rods poisoning 0.6% $\delta k/k$. The fuel salt will be sampled and the concentration measured at least once per week.
- R1 2.8 At no time during critical operation of the reactor will the reactivity anomaly be allowed to exceed 0.5% $\delta k/k$. A "reactivity anomaly" is defined as a deviation from the reactivity which is expected on the basis of measured reactor physics constants and calculated effects of burnup and fission product accumulation.
- R1 2.9 A positive period of 1 sec or less will cause a safety-rod scram.

3.0 Coolant System

- 3.1 The maximum coolant system cover-gas pressure is 50 psig.

4.0 Control Rods

- 4.1 The normal complement of control rods is three, of which two are required to scram for safety action.
- 4.2 The maximum scram time (time from initiation of signal until a rod is on the seat) is 1.3 sec.
- 4.3 The rod speed (motor powered) is 0.5 ± 0.05 in./sec. This speed permits maximum reactivity additions in "start" of 0.1% $\delta k/k$ per sec and in "run" of 0.05% $\delta k/k$ per sec.

4.0 Control Rods (continued)

- R1 4.4 The scram time of the rods will be checked before each fill with fuel salt.

5.0 Nuclear Control and Safety Instrumentation

- 5.1 All nuclear safety instrumentation will be checked for proper operation before each fill.
- R1 5.2 A minimum of two safety-level channels will be in service during reactor operation.
- 5.3 A minimum of two reactor-fuel-outlet temperature signals will be in service during reactor operation.
- 5.4 A minimum of one fission chamber with count-rate circuit must be in operation during startup filling operations.
- R1 5.5 A minimum of two positive period safety channels will be in service during reactor operation.

6.0 Personnel Radiation Monitoring

6.1 Radiation level monitors

A minimum of two personnel radiation monitors will be in operation at all times, one in the high-bay area and one in the control-room area.

6.2 Air monitors

A minimum of two air activity monitors will be in operation at all times, one in the high-bay area and one in the office— control-room area.

7.0 Personnel and Procedures

7.1 Personnel qualifications


The reactor will be operated only by qualified personnel approved by the Chief of Operations. It will be operated in conformance with documented operating procedures which, in no instance, designate authorization to operate the reactor in excess of any operating safety limits listed above.

7.0 Personnel and Procedures (continued)

7.2 The minimum staff requirement for operation during any shift is that at least one supervisor and two technicians will be on duty during reactor operation. The control room will not be left unattended while fuel is in the reactor vessel.

8.0 Experimental Limits

Experiments will be conducted within the limits specified in this report. Experimental procedures will be approved in advance by the Head of the Operations Department, Oak Ridge National Laboratory Reactor Division, or his authorized assistant.



Internal Distribution

- | | |
|-----------------------|--|
| 1. G. M. Adamson | 31. H. F. McDuffie |
| 2. R. G. Affel | 32. C. K. McGlothlan |
| 3. S. E. Beall | 33. A. J. Miller |
| 4. F. F. Blankenship | 34. R. L. Moore |
| 5. R. Blumberg | 35. H. R. Payne |
| 6. C. J. Borkowski | 36. A. M. Perry |
| 7. R. B. Briggs | 37. H. B. Piper |
| 8. G. H. Burger | 38. J. L. Redford |
| 9. W. B. Cottrell | 39. H. C. Roller |
| 10. J. L. Crowley | 40. M. W. Rosenthal |
| 11. F. L. Culler | 41. Ann Savolainen |
| 12. J. R. Engel | 42. D. Scott, Jr. |
| 13. E. P. Epler | 43. M. J. Skinner |
| 14. A. P. Fraas | 44. A. N. Smith |
| 15. C. H. Gabbard | 45. I. Spiewak |
| 16. R. B. Gallaher | 46. R. C. Steffy |
| 17. W. R. Grimes | 47. J. R. Tallackson |
| 18. R. H. Guymon | 48. R. E. Thoma |
| 19. P. H. Harley | 49. D. B. Trauger |
| 20. P. N. Haubenreich | 50. W. C. Ulrich |
| 21. V. D. Holt | 51. B. H. Webster |
| 22. T. L. Hudson | 52. A. M. Weinberg |
| 23. P. R. Kasten | 53. M. E. Whatley |
| 24. A. I. Krakoviak | 54. G. D. Whitman |
| 25. R. B. Lindauer | 55-56. Central Research Library |
| 26. M. I. Lundin | 57-58. Y-12 Document Reference Section |
| 27. R. N. Lyon | 59-61. Laboratory Records Department |
| 28. H. G. MacPherson | 62. Laboratory Records, RC |
| 29. R. E. MacPherson | 63. C. E. Larson |
| 30. H. C. McCurdy | 64. S. J. Ditto |

External Distribution

- 65-79. Division of Technical Information Extension, DTIE
- 80-81. Reactor Division, AEC, ORO
 - 82. A. Giambusso, AEC, Washington
- 83-86. H. M. Roth, Division of Research and Development, AEC, ORO
 - 87. W. L. Smalley, Reactor Division, AEC, ORO
 - 88. M. J. Whitman, AEC, Washington