
#### Economic Evaluation of Residential Air Conditioner Designs for Hot and Dry Climates

Arthur Rosenfeld, California Energy Commission Gregory Rosenquist, Lawrence Berkeley National Laboratory C. Keith Rice, Oak Ridge National Laboratory

> ARI Spring Product Section Meeting Reston, VA. April 18, 2005, modified on 4-20

ARosenfe@Energy.State.CA.US


## California has lower per capita electricity use than the rest of the country



### Daily peak loads in California are highest during the summer

Cal ISO Daily Peak Loads

January 1, 2000 - December 31, 2000




# DOE has funded research at ORNL to develop A/C designs for hot/dry climates

- Several Hot/Dry designs were developed by ORNL relative to a conventional baseline design
- Three Hot/Dry designs were adapted for economic evaluation
  - Baseline design: 13 SEER, R-410A
  - Hot/Dry designs
    - Design 1: 1.4X Evap HX surface area
    - Design 2: 1.4X Evap HX surface area; ECM Blower Motor
    - Design 3: 1.4X Evap HX surface area; ECM Blower Motor; Rated Ducts

	5	System	Evaporator				Compressor Percent of	Ducts
Design	SEER	Hot/Dry EER Out: 115°F In: 80°F/62°F	Face Area Sq.ft.	<b>Flow</b> CFM	<b>Fan Power</b> 115°F; 80/62°F <i>Watts</i>	<b>Evap Temp</b> Out: 95°F In: 80°F/67°F	Baseline Displacemen t	<b>Type / Ext. Static</b> Inches H <sub>2</sub> O
Baseline	13.1	7.5	5.0	1200	355	48°F	-	Typical / 0.5"@1200 CFM
Design 1	13.8	8.0	7.2	1200	330	52°F	94%	Typical / 0.5"@1200 CFM
Design 2	14.6	8.4	7.2	1200	265	52°F	91%	Typical / 0.5"@1200 CFM
Design 3	15.4	9.2	7.2	1500	250	55°F	84%	Rated / 0.15" fixed

# Designs evaluated at multiple temperatures for purposes of modeling in a typical house


- Baseline and three Hot/Dry designs were simulated with the ORNL Heat Pump Design Model, Mark VI, at four sets of outdoor dry bulb/indoor wet bulb temperature conditions
  - More efficient designs maintain their efficiency advantage regardless of temperature conditions
  - Compressor downsized to match baseline capacity-- hot/dry design condition




# Prototypical house chosen for two hot/dry locations: Fresno, CA and Phoenix, AZ

- California prototypical house for Fresno
- Fresno house modeled in Phoenix (only weather changed)
- Both locations modeled with DOE-2
  - Square footage: 2258 sq.ft.
  - Number of floors: 2
  - Floor type: Slab-on-grade
  - Exterior wall
    - Area: 1584 sq.ft.
    - Insulation: R-13
  - Ceiling insulation: R-30
  - Windows
    - Area: 251 sq.ft.
    - Window-to-Wall Ratio: 16%
    - R-value: R-1.2 (double-glazing)

# Designs yield both annual energy and peak demand savings in Fresno



# Designs yield both annual energy and peak demand savings in Phoenix



#### **CEC-PIER Hot-Dry a/c Proof of Concept Project**

- Proctor Engineering et al. have modified Keith Rice's Designs and built two early prototypes optimized for California a/c loads, one 3-ton residential split system, one 5-ton commercial package unit. Actual measurements to date support the calculations provided in earlier slides
- See <u>http://www.hdac-des-pier.com/project.html</u>


### **Residential electric utility tariffs used to calculate bills**

- Fresno: Pacific Gas & Electric Co.
- Schedule E-1 Residential Service (Zone R) (Effective March 1, 2004)
  - Monthly Summer Charges
    - 0 to 534 kWh: 12.59 ¢/kWh
    - 534 to 694 kWh: 14.32 ¢/kWh
    - 694 to 1068 kWh: 18.15 ¢/kWh
    - 1068 to 1602 kWh: 21.43 ¢/kWh
    - Remaining kWh: 21.43 ¢/kWh
  - Monthly Winter Charges
    - 0 to 387 kWh: 12.59 ¢/kWh
    - 387 to 503 kWh: 14.32 ¢/kWh
    - 503 to 774 kWh: 18.15 ¢/kWh
    - 774 to 1161 kWh: 21.43 ¢/kWh
    - Remaining kWh: 21.43 ¢/kWh
  - Fixed Charges
    - Monthly Charge: \$5.00

- <u>Phoenix:</u> Arizona Public Service Co.
- Residential Service E-12 (Effective July 1, 2003)
  - Monthly Summer Charges
    - 0 to 400 kWh: 7.38 ¢/kWh
    - 400 to 800 kWh: 10.28 ¢/kWh
    - Remaining kWh: 11.99 ¢/kWh
  - Monthly Winter Charges
    - All kWh: 7.39 ¢/kWh
  - Fixed Charges
    - Basic Service Charge: \$7.50


## Time dependent valuation (TDV) prices are also used to calculate bills

- TDV prices are incorporated into California appliance standards (Title 20) and building standards (Title 24)
- TDV prices, or avoided costs, are independent of the idiosyncrasies of utility tariffs
- TDV prices incent efficient air conditioners




# Time dependent valuation (TDV) prices vary over the year


 Although TDV prices in some hours exceed 50 ¢/kWh, annual average TDV price equals 15 ¢/kWh



# Fresno A/C energy use can now be expressed as utility bills – PG&E and TDV



# Phoenix A/C energy use can now be expressed as utility bills – APSC and TDV



#### **Consumer price of more efficient designs increase with efficiency**


		Manufa	cturer Co	<b>∆</b> Consumer Price				
	Compressor	Evap Coil	Evap Motor	Total	∆ Cost	Δ Price	Δ Ducts	Δ Total
Baseline	\$168	\$113	\$61	\$342	-	-	-	-
Design 1	\$158	\$172	\$61	\$391	\$49	\$101	-	\$101
Design 2	\$153	\$172	\$185	\$510	\$168	\$348	-	\$348
Design 3	\$141	\$172	\$185	\$497	\$155	\$322	\$500	\$822

Manufacturer cost estimates from 2001 DOE Technical Support Document


# Cost-effectiveness of designs based upon LCC savings and payback

- Life-cycle cost (LCC) is the sum of the total installed cost plus the present value of the lifetime operating cost savings
  - For residential tariff calculations, present value of future operating cost savings calculated with a 5.6% real discount rate
  - Equipment lifetime set to 18.4 years
  - Future electricity price trends based upon DOE-EIA's 2004 Annual Energy Outlook
  - Both the discount rate and lifetime are taken from DOE's central air conditioner rulemaking analysis
- Payback period is the increase in total installed cost divided by the annual operating cost savings


# All designs provide both LCC savings and short payback periods in Fresno



#### All designs provide both better LCC savings and shorter payback periods in Phoenix



### Cost of Conserved Energy (CEE) can also be used to evaluate designs



Hour

1

3

8 9 10

11 12 13 14 15 16 17 18 19 20 21 22 23 24

#### **Summary of Analysis**

- All three Hot/Dry A/C designs developed by ORNL provide LCC savings and relatively short payback periods
  - LCC savings range from:
    - ~\$300 to ~\$1200 based on residential electric utility tariffs
    - ~\$500 to ~\$3500 based on TDV prices
  - Payback periods range from 2 to 7 years
  - LCC savings and payback periods are relative to a 13 SEER baseline design
- To exploit full savings potential:
  - Manufacturers need to offer equipment designed for Hot/Dry climates
  - California needs to revise building standards to ensure good ducts